

T&S BRASS AND BRONZE WORKS, INC.

2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690

PHONE 800-476-4103

FAX 864- 834-3518



REG.#A2601
ISO #9002

Model No.

B-CW-1/2


Item No.:

Job Name:

Architect/Engineer Approval:

Notes:

1/2" NPT FEMALE INLET
GAGE FIT ± 1 TURN



1/2" NPT FEMALE OUTLET
GAGE FIT ± 1 TURN

NOTES:

1. MAXIMUM PRESSURE 400 PSI AT 200° F
2. NOT TO BE USED FOR NATURAL GAS APPLICATIONS.

Product Description:

VERTICAL CHECK VALVE FOR WATER ONLY
WITH 1/2" NPT INLET & OUTLET

Drawn:

WJS

Approved

CA

Checked

ARY

Scale:

1' = 1'

Date:

10/2/95